



Reg. No. 041/P-007

NOTIFIED BODY 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0071

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Steel rectangular single compartment smoke control duct

designed to transport smoke and/or hot gasses away from the source of a fire, used on conditions and with fire resistance classification as described in the Determination of the product type No. C1396/13/0013/4004/SC (issued by FIRES, s.r.o., Notified Body 1396 on 20. 09. 2013), amended by an actual report of continuous surveillance. The product is

placed on the market under the name or trade mark of

INSTAL-LUBLIN S.A.

Anny Walentynowicz 9, 20-328 Lublin, Poland

and produced in the manufacturing plant(s)

INSTAL-LUBLIN S.A.

Anny Walentynowicz 9, 20-328 Lublin, Poland.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12101-7: 2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 20. 09. 2013 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 11. 09. 2020



Ing. Henrieta Lapková
Head of Product Certification Body

117183

FIRES 136a/C-31/01/2017-E